



**VALLEY TESTING AND ENGINEERING**

#18 - 3275 McCallum Road ph: 1-888-855-9733  
 Abbotsford, B.C. V2S 7W8 fax: (604) 855-7378

**SIEVE ANALYSIS REPORT  
 8 16 30 50 SERIES**

TO LINTERRA AGGREGATES

PROJECT NO. V6590  
 CLIENT LINTERRA AGGREGATES  
 C.C. LINTERRA AGGREGATES


ATTN: HELLEN HOWELL

PROJECT CULTUS LAKE AGGREGATES  
 MATERIALS TESTING  
 CONTRACTOR LINTERRA AGGREGATES

VEDDER ROAD  
 CHILLIWACK

SIEVE TEST NO. 181 DATE RECEIVED 2017.Mar.07 DATE TESTED 2017.Mar.08 DATE SAMPLED 2017.Mar.07

SUPPLIER LINTERRA AGGREGATES      SAMPLED BY CLIENT  
 SOURCE CULTUS LAKE PIT      TESTED BY CF  
 SPECIFICATION DENSIFICATION STONE      TEST METHOD ASTM C-136  
 MATERIAL TYPE 75 mm CRUSHED



GRAVEL SIZES	PERCENT PASSING	GRADATION LIMITS
3" 75 mm	100.0	100.0-100.0
2" 50 mm	86.9	
1 1/2" 37.5 mm	69.5	40.0-100.0
1" 25 mm	44.5	
3/4" 19 mm	32.4	10.0-40.0
1/2" 12.5 mm	15.6	
3/8" 9.5 mm	7.1	0.0-15.0

SAND SIZES AND FINES	PERCENT PASSING	GRADATION LIMITS
No. 4 4.75 mm	2.5	0.0-5.0
No. 8 2.36 mm	2.2	
No. 16 1.18 mm	2.0	
No. 30 600 µm	1.9	
No. 50 300 µm	1.6	
No. 100 150 µm	1.3	
No. 200 75 µm	1.3	0.0-2.0

COMMENTS

Reporting of these test results constitutes a testing service only. Engineering interpretation or evaluation of test results is provided only on written request.

Report System Control Registered: Valley Testing and Engineering Ltd. Abbotsford